

**READ AND SAVE THESE INSTRUCTIONS**

# INSTALLATION MANUAL

SPA control unit  
Condair **Delta SPA Control Box**

Humidification, Dehumidification  
and Evaporative Cooling

 **condair**

# Thank you for choosing Condair

Installation date (MM/DD/YYYY):

Commissioning date (MM/DD/YYYY):

Site:

Model:

Serial number:

## Proprietary Notice

This document and the information disclosed herein are proprietary data of Condair Ltd. Neither this document, nor the information contained herein shall be reproduced, used, or disclosed to others without the written authorization of Condair Ltd., except to the extent required for installation, operation or maintenance of the customer's equipment.

## Liability Notice

Condair Ltd. does not accept any liability due to incorrect installation, maintenance or operation of the equipment, or due to the use of parts/components/equipment that are not authorized by Condair Ltd.

## Copyright Notice

© Condair Ltd., All rights reserved.

Technical modifications reserved

# Contents

---

<b>1</b>	<b>Introduction</b>	<b>5</b>
1.1	To the very beginning	5
1.2	Notes on the installation manual	5
<b>2</b>	<b>For your safety</b>	<b>7</b>
<b>3</b>	<b>Product Overview</b>	<b>9</b>
3.1	Application overview of the Condair Delta SPA Control Box	9
3.2	Versions of the Condair Delta SPA Control Box	9
3.3	System / application overviews	10
3.3.1	Condair Delta SPA Control Box for steam bath application	11
3.3.2	Condair Delta SPA Control Box for steam bath application with optional bench heating	12
3.3.3	Condair Delta SPA Control Box for Caldarium application	13
3.3.4	Condair Delta SPA Control Box for Rasul application	14
3.4	Identification of the unit	15
3.5	Accessories	15
<b>4</b>	<b>Inspecting the delivery / Storage and Transportation</b>	<b>16</b>
4.1	Delivery	16
4.1.1	Standard delivery	16
4.1.2	Inspecting the delivery	16
4.2	Storage and Transportation	17
<b>5</b>	<b>Mounting and installation work</b>	<b>18</b>
5.1	Important notes on mounting and installation work	18
5.2	Mounting the Condair Delta SPA Control Box	19
5.2.1	Notes on locating the unit	19
5.2.2	Mounting the Condair Delta SPA Control Box	20
5.2.3	Inspecting the installed unit	21
5.3	Electric installation	22
5.3.1	Notes on electrical installation	22
5.3.2	Overview SPA cabin installations	23
5.3.3	Wiring diagrams	24
5.3.3.1	Wiring diagram Condair Delta SPA Control box for steam bath application	24
5.3.3.2	Wiring diagram Condair Delta SPA Control Box for steam bath application with optional bench heating	26
5.3.3.3	Wiring diagram Condair Delta SPA Control Box for caldarium application with bench and wall heating	28
5.3.3.4	Wiring diagram Condair Delta SPA Control Box for Rasul application with bench and wall heating	30

5.3.4	Installation work external connections	32
5.3.4.1	Connection of switch "S1" and buttons "S2" to "S4"	32
5.3.4.2	Connection of the temperature sensor "A1" for monitoring the cabin temperature	33
5.3.4.3	Connection of the humidity sensor "A2"	34
5.3.4.4	Connection of the temperature sensor "A3" of the bench heating	34
5.3.4.5	Connection of the temperature sensor "A4" of the wall heating	35
5.3.4.6	Connection of the demand signal "A5" for controlling the steam generator	35
5.3.4.7	Connection of the cabin overtemperature switch "A6"	36
5.3.4.8	Connection of fragrance pumps "M1" and "M2" (120 VAC)	37
5.3.4.9	Connecting the cabin light "E1" and "E2"	38
5.3.4.10	Connection of the fans "M3"/"M4" (two fan operation)	39
5.3.4.11	Connection of the optional bench heating for steam bath application	40
5.3.4.12	Connection of the bench heating and the wall heating for Caldarium and Rasul application	41
5.3.4.13	Connection of the relays "Rel 8" and "Rel 9"	42
5.3.4.14	Connection of the fault output "Err. Out"	43
5.3.4.15	Connection of external safety chain	43
5.3.4.16	Connecting the external SPA display(s) (accessory)	44
5.3.4.17	Power supplies	48
5.3.5	Connection data accessories	50
5.3.6	Inspecting the electrical installation	51
<b>6</b>	<b>Appendix</b>	<b>52</b>
6.1	Dimensions of the Condair Delta SPA Control Box	52

# 1 Introduction

---

## 1.1 To the very beginning

We thank you for having purchased the **Condair Delta SPA Control Box**.

The Condair Delta SPA Control Box incorporates the latest technical advances and meets all recognized safety standards. Nevertheless, improper use of the Condair Delta SPA Control Box may result in danger to the user or third parties and/or damage to property.

To ensure a safe, proper, and economical operation of the Condair Delta SPA Control Box, please observe and comply with all information and safety instructions contained in the present documentation as well as in the separate documentations of the components used together with the Condair Delta SPA Control Box.

If you have questions after reading this documentation, please contact your Condair representative. They will be glad to assist you.

## 1.2 Notes on the installation manual

### Limitation

**The subject of this installation manual is the Condair Delta SPA Control Box in its different versions.** The various options and accessories are only described insofar as is necessary for proper operation of the equipment. Further information on options and accessories can be obtained in their respective instructions.

This installation manual is restricted to the **installation** of the Condair Delta SPA Control Box and is meant for **well trained specialists being sufficiently qualified for their respective work**.

This installation manual is supplemented by various separate items of documentation (operation manual, spare parts list, etc.), which are included in the delivery as well. Where necessary, appropriate cross-references are made to these publications in the installation manual.

## Symbols used in this manual



### CAUTION!

The catchword "CAUTION" used in conjunction with the general caution symbol designates notes in this installation manual that, if neglected, may cause **damage and/or malfunction of the unit or damage to property**.



### WARNING!

The catchword "WARNING" used in conjunction with the general caution symbol designates safety and danger notes in this installation manual that, if neglected, may cause **injury to persons**.



### DANGER!

The catchword "DANGER" used in conjunction with the general caution symbol designates safety and danger notes in this installation manual that, if neglected, may lead to **severe injury or even death of persons**.

## Safekeeping

Please safeguard this installation manual in a safe place, where it can be immediately accessed. If the equipment changes hands, the documentation must be passed on to the new operator.

If the documentation gets misplaced, please contact your Condair representative.

## Language versions

This installation manual is available in other languages. Please contact your Condair representative for information.

## 2 For your safety

---

### General

Every person, who is in charge of the installation work on the Condair Delta SPA Control Box must have read and understood this installation manual and the Condair Delta SPA Control Box operation manual before carrying out any work.

Knowing and understanding the contents of this installation manual as well as the operation manual of the Condair Delta SPA Control is a basic requirement for protecting personnel against any kind of danger, to prevent faulty operation, and to operate the unit safely and correctly.

All icons, signs and markings applied to the Condair Delta SPA Control Box must be observed and kept in readable state.

### Qualification of personnel

All installation work described in this installation manual **may only be carried out by specialists who are well trained and adequately qualified and are authorised by the customer.**

For safety and warranty reasons any action beyond the scope of this manual must be carried out only by qualified personnel authorised by Condair Ltd.

It is assumed that all persons working with the Condair Delta SPA Control Box are familiar and comply with the appropriate regulations on work safety and the prevention of accidents.

### Intended use

**The Condair Delta SPA Control Box is intended exclusively for the operating control (non-safety related) of Steam Baths, Caldariums and Rasul according to the information contained in this installation manual and in the SPA control software operation manual within the specified operating conditions.** Any other type of application, without the written consent of Condair Ltd., is considered as not conforming with the intended purpose and may lead to the Condair Delta SPA Control Box becoming dangerous and will void any warranty.

Operation of the equipment in the intended manner requires **that all the information contained in this installation manual and in the SPA control software operation manual are observed (in particular all safety instructions).**

## Danger that may arise from the Condair Delta SPA Control Box



**DANGER!**

Danger of electric shock!

**The Condair Delta SPA Control Box is mains powered. Live parts may be exposed when the unit is open. Touching live parts may cause severe injury or danger to life.**

**Prevention:** The Condair Delta SPA Control Box must be connected to the mains only after all mounting and installation work has been completed, all installations have been checked for correct workmanship and the unit is closed and properly locked.



**WARNING!**

**Battery may explode if mistreated. Do not recharge, disassemble or dispose of in fire.**

### Preventing unsafe operation

All persons working with the Condair Delta SPA Control Box are obliged to report any alterations to the unit that may affect safety to the owner without delay and to **secure the Condair Delta SPA Control Box against accidental power-up.**

### Prohibited modifications to the unit

**No modifications must be undertaken** on the Condair Delta SPA Control Box without the express written consent of Condair.

For the replacement of defective components use exclusively **original accessories and spare parts** available from your Condair representative.

### Additional information

Type 1.C Action	
Pollution Degree	2
Impulse Voltage	2.5 kV

### 3 Product Overview

#### 3.1 Application overview of the Condair Delta SPA Control Box

The Condair Delta SPA Control Box is available in different versions for different applications in the SPA sector.

Application	Description	Control of the cabin climate	Accessories											
			Light		Ventilation		Duftstoff		Additional relays		Shower		Heating	
Light 1 (Cleaning or color light)	Light 2 (Cleaning or color light)	Fan 1 (Supply or exhaust fan)	Fan 2 (Supply or exhaust fan)	Fragrance 1 (Pump 1)	Fragrance 2 (Pump 2)	Music, ... (Rel 8)	Music, ... (Rel 9)	Showers (Pump 2)	Bench heating (Rel 8)	Wall heating (Rel 8)				
Steam bath	Steam bath cabin supplied with steam from a steam generator. The humidity in the steam cabin is almost 100%. The heat is generated by the supplied steam and the optional bench heating in the cabin.	Temperature control up to 50 °C	x x x x x	x x	x x	(x)	x	–	–	–	(x)	–		
Caldarium	Steam cabin supplied with steam from a steam generator. The humidity in the cabin is almost 70%. The heat is generated by the wall heating and the bench heating in the cabin.	Humidity control up to 80% rh	x x x x x	x x x	x x	–	–	–	–	–	x	x		
Rasul	Steam cabin supplied with steam from a steam generator. The humidity in the cabin is almost 70%. The heat is generated by the wall heating and the bench heating in the cabin.	Humidity control up to 80% rh	x x x x x	x –	– – –	–	–	x	x	x				

#### 3.2 Versions of the Condair Delta SPA Control Box

Application / Cabin type	Hardware equipment Condair Delta SPA Control Box	Steam generation / Steam generator
Steam bath <b>without</b> bench heating	Condair Delta SPA Control Box with standard equipment	Steam generator(Condair EL, Condair RS, etc.)
	Condair Delta SPA Control Box with standard equipment	Condair Omega with Omega Control
Steam bath <b>with</b> bench heating	Condair Delta SPA Control Box with equipment for bench heating	Steam generator(Condair EL, Condair RS, etc.)
	Condair Delta SPA Control Box with equipment for bench heating	Condair Omega with Omega Control
Caldarium	Condair Delta SPA Control Box with equipment for bench and wall heating	Steam generator(Condair EL, Condair RS, etc.)
	Condair Delta SPA Control Box with equipment for bench and wall heating	Condair Omega with Omega Control
Rasul	Condair Delta SPA Control Box with equipment for bench and wall heating	Steam generator(Condair EL, Condair RS, etc.)
	Condair Delta SPA Control Box with equipment for bench and wall heating	Condair Omega with Omega Control

### 3.3 System / application overviews

The following chapters contain the corresponding system / application overviews. The following symbols are used in these system overviews.

	Fan 1 / 2 (Control of supply or exhaust fan)		On/Off button SPA operation
	Light 1 / 2 (Control of cleaning or color light)		Steam (Steam generated by an external steam generator or the integrated water reservoir of the Bio sauna)
	Heating 1 / 2 (e.g. control of sauna heater, bench heating, etc.)		Shower (Control of the cabin shower for Rasul application)
	Fragrance 1 / 2 (Control of fragrance pump 1 / 2)		Speaker (Control of music)
	Temperature sensor (Measurement of cabin temperature, bench temperature, etc.)		Power supply
	Humidity sensor (Measurement of cabin humidity)		Water supply steam generator
	Door contact		Water drain steam generator

### 3.3.1 Condair Delta SPA Control Box for steam bath application




Fig. 1: Condair Delta SPA Control Box for steam bath application

### 3.3.2 Condair Delta SPA Control Box for steam bath application with optional bench heating




Fig. 2: Condair Delta SPA Control Box for steam bath application with optional bench heating

### 3.3.3 Condair Delta SPA Control Box for Caldarium application




Fig. 3: Condair Delta SPA Control Box for Caldarium application

### 3.3.4 Condair Delta SPA Control Box for Rasul application




Fig. 4: Condair Delta SPA Control Box for Rasul application

### 3.4 Identification of the unit

The identification of the unit is found on the rating plate:

Type designation (DSC, DSC-BH or DSC-BWH)	Serial number (7 digits)	Month/Year
Control voltage	Condair Group AG, Gwattstrasse 17, 8808 Pfäffikon SZ, Switzerland	
Typical power consumption	Type: Condair DSC	Serial No.: XXXXXXX 11.23
Field with certification symbols	Control voltage: 120V/1~/ 60Hz	Amps: xx A
	Power: x.x kW	Circuit protection: Max. xx A
	 LISTED	File: Exxxxxx
		Engineered in Switzerland, Made in Germany
Typical Amperage		
Max. circuit protection		




Fig. 5: Location of the rating plate

### 3.5 Accessories

A separate product documentation is available for accessories for the Condair Delta SPA Control Box and for SPA applications. Please contact your Condair representative.

## 4 Inspecting the delivery / Storage and Transportation

---

### 4.1 Delivery

#### 4.1.1 Standard delivery

The standard delivery includes:

- Condair Delta SPA Control Box including fixing set, installation manual (this document) and operation manual SPA Control and spare parts list, packaged in cardboard box.

Unit type	Dimensions packaging (L x W x D)	Transport weight
Condair Delta SPA Control Box	16.85 in x 16.81 in x 6.77 in (428 mm x 427 mm x 172 mm)	13.23 lbs (6.0 kg)

- Ordered accessories with operating instructions packed separately.

#### 4.1.2 Inspecting the delivery

After receiving:

- Inspect shipping box(es) for damage.  
Any damages of the shipping box(es) must be reported to the shipping company without delay.
- Check packing slip to ensure all parts has been delivered.  
All material shortages are to be reported to your Condair supplier within 48 hours after receipt of the goods. Condair Ltd. assumes no responsibility for any material shortages beyond this period.
- Unpack the parts/components and check for any damage.  
If parts/components are damaged, notify the shipping company immediately.
- Check whether the components are suitable for installation on your site according to the unit data stated on the rating plate.

## 4.2 Storage and Transportation

### Storing

Until installation store the Condair Delta SPA Control Box Pro in its original packaging in a protected area meeting the following requirements:

- Room temperature: 41 ... 104 °F (5 ... 40 °C)
- Room humidity: 10 ... 75 %rh

### Transportation

For optimum protection always transport the unit and components in their original packaging and use appropriate lifting/transporting devices.



#### WARNING!

It is the customer's responsibility to ensure that operators are trained in handling goods and that the operators comply with the appropriate regulations on work safety and the prevention of accidents.

### Packaging

Keep the original packaging of the components for later use.

In case you wish to dispose of the packaging, observe the local regulations on waste disposal. Please recycle packaging where possible.

## 5 Mounting and installation work

### 5.1 Important notes on mounting and installation work

#### Qualification of personnel

All mounting and installation work must be carried out only by **well qualified specialists authorised by the owner**. It is the owner's responsibility to verify proper qualification of the personnel.

The electrical installations may only be carried out by a trained electrician.

#### General notes

Strictly observe and comply with all information and safety instructions in the present installation manual as well as in the documentations for the components (steam generator, sensors, fans, etc.), which are installed and used together with the Condair Delta SPA Control Box.

Observe and comply with all local regulations dealing with water, steam and electrical installations.

#### Safety

Some installation work requires removal of the unit cover of the Condair Delta SPA Control Box. Please note the following:



**DANGER!**

**Danger of electric shock!**

**The Condair Delta SPA Control Box is mains powered. Live parts may be exposed when the unit is open. Touching live parts may cause severe injury or danger to life.**

**Prevention:** The Condair Delta SPA Control Box must be connected to the mains only after all mounting and installation work has been completed, all installations have been checked for correct workmanship and the unit is closed and properly locked.



**CAUTION!**

**The electronic components inside the Condair Delta SPA Control Box and inside the steam generator are very sensitive to electrostatic discharge.**

**Prevention:** To protect these components against damage caused by electrostatic discharge (ESD protection) appropriate measures must be taken when the unit(s) is/are open for installation work.

## 5.2 Mounting the Condair Delta SPA Control Box

### 5.2.1 Notes on locating the unit

For the positioning of the Condair Delta SPA Control Box the following points must be observed and adhered to:

- The Condair Delta SPA Control Box is designed for wall-mounting in protected interiors. Make sure that the construction (wall, pillar, floor-mounted console, etc.) to which the Condair Delta SPA Control Box is to be mounted, offers a **sufficiently high load-bearing capacity** (take notice of the weight information), and is suitable for the installation.
- Install the Condair Delta SPA Control Box in such a manner that it is **freely accessible** with sufficient space available for installation and operation purposes.
- The Condair Delta SPA Control Box is **IP22** protected. Nevertheless, care should be taken to ensure that the device is protected from splash water at the installation site and that the permissible ambient conditions are complied with.
- The Condair Delta SPA Control Box must not be installed in potentially explosive environments or inside the SPA cabin.
- When mounting the Condair Delta SPA Control Box use **only the mounting materials supplied with the unit**. If mounting with the materials supplied is not possible in your particular case, select a method of mounting that is of similar stability.
- The Condair Delta SPA Control Box is designed for installation and operation within buildings (admissible temperature range 5...40 °C).

## 5.2.2 Mounting the Condair Delta SPA Control Box




Fig. 6: Mounting the Condair Delta SPA Control Box

### Procedure

1. Mark the three attachment points at the desired position with the help of a spirit level. Then, drill holes diameter: 0.39" (10 mm), depth: 1.97" (50 mm).
2. Insert the supplied plastic plugs.
3. Unlock the retaining screw of the unit cover, then remove the unit cover.
4. Fix the Condair Delta SPA Control Box to the wall using the supplied screws and washers, align horizontally with a spirit level and tighten the screws.  
**Important: Make sure that the washers are mounted underneath the screw heads.**
5. Reattach the unit cover and lock it with the screws and gaskets.  
**Important: Make sure the gaskets are located underneath the screw heads.**

### 5.2.3 Inspecting the installed unit

Check the following points:

- Is the Condair Delta SPA Control Box installed in the correct place (see [chapter 5.2.1](#))?
- Is the supporting surface stable enough?
- Is the Condair Delta SPA Control Box correctly aligned, vertically and horizontally?
- Is the Condair Delta SPA Control Box properly secured (see [chapter 5.2.2](#))?
- Has the unit cover been relocated and correctly fixed with the two screws and gaskets?

## 5.3 Electric installation

### 5.3.1 Notes on electrical installation



**DANGER!**

Danger of electric shock

The Condair Delta SPA Control Box is mains powered. Live parts may be exposed when the unit is open. Touching live parts may cause severe injury or danger to life.

**Prevention:** The Condair Delta SPA Control Box unit must be connected to the mains only after all mounting and installation work has been completed, all installations have been checked for correct workmanship and the unit is closed and properly locked.



**CAUTION!**

The electronic components inside the Condair Delta SPA Control Box are very sensitive to electrostatic discharge. Before carrying out installations work inside the unit, appropriate measures must be taken to protect the electronic components against damage caused by electrostatic discharge (ESD protection).



**WARNING!**

For public saunas without heating time limit, a warning light in the room of the supervisor must be installed, which indicates when the sauna heater is on.

- All work concerning the electrical installation must be performed only by **skilled and qualified technical personnel (e.g. electrician with appropriate training) authorised by the owner**. It is the owner's responsibility to verify proper qualification of the personnel.
- The electrical installation must be carried out according to the corresponding wiring diagram (see [chapter 5.3.3](#)), the notes on electrical installation as well as the applicable local regulations. All information given in the wiring diagram and additional notes regarding the electrical installation work must be followed and observed.
- All cables must be lead into the unit, via appropriate cable glands with strain relief (supplied by others). Make sure that the cable glands with splash-water protection are used and that they are watertight.
- Make sure the cables are adequately fixed, do not rub on any components or become a tripping hazard.
- Observe and maintain maximum cable length and required cross section per wire according to local regulations.
- Only use heat-resistant cables designed for a temperature of at least 150 °C to connect the accessory components in the cabin.
- The mains supply voltage(s) must match the respective voltage(s) stated in the corresponding wiring diagram (see [chapter 5.3.3](#)).
- Make sure that the maximum permissible loads are not exceeded (see [chapter 5.3.5](#)).
- For the installation of accessory components, please observe the information in the corresponding documentation supplied by the respective manufacturer.

### 5.3.2 Overview SPA cabin installations





Fig. 7: Overview SPA cabin installations

## 5.3.3 Wiring diagrams


### 5.3.3.1 Wiring diagram Condair Delta SPA Control box for steam bath application



## Legend wiring diagram Condair Delta SPA Control box for steam bath application

Symbol	Description	Remarks	Technical details
<b>A1</b>	Temperature sensor with integrated overtemperature switch	Detecting of the cabin temperature	KTY, PT100, PT1000
<b>A5</b>	Demand signal for external steam generator		0-10 V
<b>B3</b>	Safety devices (e.g. emergency stop)		
<b>BAT</b>	Backup battery SPA control board		CR2032, Lithium 3V
<b>D1 / D2</b>	External SPA display(s)	See notes in <a href="#">chapter 5.3.4.16</a>	
<b>E1</b>	Light 1	Configurable as cleaning or color light	Maximum load: 250 V, 1 A
<b>E2</b>	Light 2	Configurable as cleaning or color light	Maximum load: 250 V, 1 A
<b>Err.Out</b>	Fault output		
<b>F1</b>	Microfuse fans		2 A, slow acting
<b>F2</b>	Microfuse 24 VDC external		1 A, slow acting
<b>F3</b>	Internal fuse terminal power supply		2 A, slow acting
<b>F4</b>	Microfuse light		2 A, slow acting
<b>F5</b>	Internal fuse terminal Relais 8		2 A, fast acting
<b>F6</b>	Internal fuse terminal Relais 9		2 A, fast acting
<b>F7</b>	External fuse power supply 120 V/1~/50..60 Hz	Supplied by others!	10 A, fast acting
<b>J1</b>	Cable bridge	Connect cable bridge to terminal block "X6", if no safety devices are connected to terminal block "X6".	
<b>J2</b>	Cable bridge	Connect cable bridge to terminals 2 and 3 of terminal block "X2", if no door switch is connected.	
<b>J3</b>	Cable bridge	<b>Do not remove!</b>	
<b>J4</b>	Cable bridge	Connect cable bridge to terminal block "X2", if no overtemperature switch is connected.	
<b>JP1</b>	Terminating resistor CAN BUS	Remove jumper, if both CAN BUS connectors are used.	
<b>M1</b>	Fragrance pump 1	 <b>DANGER: 120 V output!</b>	Maximum load: 250 V, 0.5 A
<b>M2</b>	Fragrance pump 2	 <b>DANGER: 120 V output!</b>	Maximum load: 250 V, 0.5 A
<b>M3</b>	Fan 1 (single-stage)	Control of supply and exhaust fan (configurable)	Maximum load: 250 V, 1 A
<b>M4</b>	Fan 2 (single-stage)	Control of supply and exhaust fan (configurable)	Maximum load: 250 V, 1 A
<b>RJ45</b>	Network connector	Network connector for the upload of software updates	
<b>Rel 8</b>	Potential-free relay contact	Function freely configurable	Maximum load: 250 V, 2 A
<b>Rel 9</b>	Potential-free relay contact	Function freely configurable	Maximum load: 250 V, 2 A
<b>SC</b>	Safety loop		
<b>SF</b>	Ferrite CAN BUS		
<b>SW1</b>	Rotary switch unit address	See notes in <a href="#">chapter 5.3.4.16</a>	
<b>S1</b>	Door switch		
<b>S2</b>	Start-/Stop button		
<b>S3</b>	Light 1 button		
<b>S4</b>	Light 2 / Steam blast button		
<b>Q</b>	External main switch (all-pole disconnection) power supply	Supplied by others!	


### 5.3.3.2 Wiring diagram Condair Delta SPA Control Box for steam bath application with optional bench heating



**Legend wiring diagram Condair Delta SPA Control box for steam bath application with optional bench heating**

Symbol	Description	Remarks	Technical details
<b>A1</b>	Temperature sensor with integrated over-temperature switch	Detecting of the cabin temperature	KTY, PT100, PT1000
<b>A3</b>	Temperature sensor bench heating	Detecting of the bench temperature	KTY, PT100, PT1000
<b>A5</b>	Demand signal for external steam generator		0-10 V
<b>B3</b>	Safety devices (e.g. emergency stop)		
<b>BAT</b>	Backup battery SPA control board		CR2032, Lithium 3V
<b>D1 / D2</b>	External SPA display(s)	See notes in <a href="#">chapter 5.3.4.16</a>	
<b>E1</b>	Light 1	Configurable as cleaning or color light	Maximum load: 250 V, 1 A
<b>E2</b>	Light 2	Configurable as cleaning or color light	Maximum load: 250 V, 1 A
<b>Err.Out</b>	Fault output		
<b>F1</b>	Microfuse fans		2 A, slow acting
<b>F2</b>	Microfuse 24 VDC external		1 A, slow acting
<b>F3</b>	Internal fuse terminal power supply		2 A, slow acting
<b>F4</b>	Microfuse light		2 A, slow acting
<b>F5</b>	Internal fuse terminal Relais 8		6.3 A, fast acting
<b>F6</b>	Internal fuse terminal Relais 9		2 A, fast acting
<b>F7</b>	External fuse power supply 120 V/1~/50..60 Hz	Supplied by others!	16 A, fast acting
<b>H1</b>	Bench heating	 <b>Observe safety notes in <a href="#">chapter 5.3.4.11</a>!</b>	Maximum load: 0.75 kW
<b>J1</b>	Cable bridge	Connect cable bridge to terminal block "X6", if no safety devices are connected to terminal block "X6".	
<b>J2</b>	Cable bridge	Connect cable bridge to terminals 2 and 3 of terminal block "X2", if no door switch is connected.	
<b>J3</b>	Cable bridge	<b>Do not remove!</b>	
<b>J4</b>	Cable bridge	Connect cable bridge to terminal block "X2", if no overtemperature switch is connected.	
<b>JP1</b>	Terminating resistor CAN BUS	Remove jumper, if both CAN BUS connectors are used.	
<b>M1</b>	Fragrance pump 1	 <b>DANGER: 120 V output!</b>	Maximum load: 250 V, 0.5A
<b>M2</b>	Fragrance pump 2	 <b>DANGER: 120 V output!</b>	Maximum load: 250 V, 0.5A
<b>M3</b>	Fan 1 (single-stage)	Control of supply and exhaust fan (configurable)	Maximum load: 250 V, 1 A
<b>M4</b>	Fan 2 (single-stage)	Control of supply and exhaust fan (configurable)	Maximum load: 250 V, 1 A
<b>RJ45</b>	Network connector	Network connector for the upload of software updates	
<b>Rel 8</b>	Potential-free relay contact	Used for the control of the bench heating	Maximum load: 250 V, 6.3 A
<b>Rel 9</b>	Potential-free relay contact	Function freely configurable	Maximum load: 250 V, 2 A
<b>SC</b>	Safety loop		
<b>SF</b>	Ferrite CAN BUS		
<b>SW1</b>	Rotary switch unit address	See notes in <a href="#">chapter 5.3.4.16</a>	
<b>S1</b>	Door switch		
<b>S2</b>	Start-/Stop button		
<b>S3</b>	Light 1 button		
<b>S4</b>	Light 2 / Steam blast button		
<b>Q</b>	External main switch (all-pole disconnection) power supply	Supplied by others!	


### 5.3.3.3 Wiring diagram Condair Delta SPA Control Box for caldarium application with bench and wall heating



**Legend wiring diagram Condair Delta SPA Control box for caldarium application with bench and wall heating**

Symbol	Description	Remarks	Technical details
<b>A2</b>	Humidity sensor	Caldarium	
<b>A3</b>	Temperature sensor bench heating	Detecting of the bench temperature for the control of bench heating	KTY, PT100, PT1000
<b>A4</b>	Temperature sensor wall heating	Detecting of the wall temperature for the control of wall heating	KTY, PT100, PT1000
<b>A5</b>	Demand signal for external steam generator		0-10 V
<b>A6</b>	Cabin overtemperature switch		
<b>B3</b>	Safety devices (e.g. emergency stop)		
<b>BAT</b>	Backup battery SPA control board		CR2032, Lithium 3V
<b>D1 / D2</b>	External SPA display(s)	See notes in <a href="#">chapter 5.3.4.16</a>	
<b>E1</b>	Light 1	Configurable as cleaning or color light	Maximum load: 250 V, 1 A
<b>E2</b>	Light 2	Configurable as cleaning or color light	Maximum load: 250 V, 1 A
<b>Err.Out</b>	Fault output		
<b>F1</b>	Microfuse fans		2 A, slow acting
<b>F2</b>	Microfuse 24 VDC external		1 A, slow acting
<b>F3</b>	Internal fuse terminal power supply		2 A, slow acting
<b>F4</b>	Microfuse light		2 A, slow acting
<b>F5</b>	Internal fuse terminal Relais 8		6.3 A, fast acting
<b>F6</b>	Internal fuse terminal Relais 9		6.3 A, fast acting
<b>F7</b>	External fuse power supply 120 V/1~/50..60 Hz	Supplied by others!	20 A, fast acting
<b>H1</b>	Bench heating	 <b>Observe safety notes in <a href="#">chapter 5.3.4.12!</a></b>	Maximum load: 0.75 kW
<b>H2</b>	Wall heating	 <b>Observe safety notes in <a href="#">chapter 5.3.4.12!</a></b>	Maximum load: 0.75 kW
<b>J1</b>	Cable bridge	Connect cable bridge to terminal block "X6", if no safety devices are connected to terminal block "X6".	
<b>J2</b>	Cable bridge	Connect cable bridge to terminals 2 and 3 of terminal block "X2", if no door switch is connected.	
<b>J3</b>	Cable bridge	<b>Do not remove!</b>	
<b>J4</b>	Cable bridge	Connect cable bridge to terminal block "X2", if no overtemperature switch "A6".	
<b>JP1</b>	Terminating resistor CAN BUS	Remove jumper, if both CAN BUS connectors are used.	
<b>M1</b>	Fragrance pump 1	 <b>DANGER: 120 V output!</b>	Maximum load: 250 V, 0.5A
<b>M2</b>	Fragrance pump 2	 <b>DANGER: 120 V output!</b>	Maximum load: 250 V, 0.5A
<b>M3</b>	Fan 1 (single-stage)	Control of supply and exhaust fan (configurable)	Maximum load: 250 V, 1 A
<b>M4</b>	Fan 2 (single-stage)	Control of supply and exhaust fan (configurable)	Maximum load: 250 V, 1 A
<b>RJ45</b>	Network connector	Network connector for the upload of software updates	
<b>Rel 8</b>	Potential-free relay contact	Used for the control of the bench heating	Maximum load: 250 V, 6.3 A
<b>Rel 9</b>	Potential-free relay contact	Used for the control of the wall heating	Maximum load: 250 V, 6.3 A
<b>SC</b>	Safety loop		
<b>SF</b>	Ferrite CAN BUS		
<b>SW1</b>	Rotary switch unit address	See notes in <a href="#">chapter 5.3.4.16</a>	
<b>S1</b>	Door switch		
<b>S2</b>	Start-/Stop button		
<b>S3</b>	Light 1 button		
<b>S4</b>	Light 2 / Steam blast button		
<b>Q</b>	External main switch (all-pole disconnection) power supply	Supplied by others!	

#### 5.3.3.4 Wiring diagram Condair Delta SPA Control Box for Rasul application with bench and wall heating




**Legend wiring diagram Condair Delta SPA Control box for Rasul application with bench and wall heating**


Symbol	Description	Remarks	Technical details
<b>A2</b>	Humidity sensor	Rasul	
<b>A3</b>	Temperature sensor bench heating	Detecting of the bench temperature for the control of bench heating	KTY, PT100, PT1000
<b>A4</b>	Temperature sensor wall heating	Detecting of the wall temperature for the control of wall heating	KTY, PT100, PT1000
<b>A5</b>	Demand signal for external steam generator		0-10 V
<b>A6</b>	Cabin overtemperature switch		
<b>B3</b>	Safety devices (e.g. emergency stop)		
<b>BAT</b>	Backup battery SPA control board		CR2032, Lithium 3V
<b>D1 / D2</b>	External SPA display(s)	See notes in <a href="#">chapter 5.3.4.16</a>	
<b>E1</b>	Light 1	Configurable as cleaning or color light	Maximum load: 250 V, 1 A
<b>E2</b>	Light 2	Configurable as cleaning or color light	Maximum load: 250 V, 1 A
<b>Err.Out</b>	Fault output		
<b>F1</b>	Microfuse fans		2 A, slow acting
<b>F2</b>	Microfuse 24 VDC external		1 A, slow acting
<b>F3</b>	Internal fuse terminal power supply		2 A, slow acting
<b>F4</b>	Microfuse light		2 A, slow acting
<b>F5</b>	Internal fuse terminal Relais 8		6.3 A, fast acting
<b>F6</b>	Internal fuse terminal Relais 9		6.3 A, fast acting
<b>F7</b>	External fuse power supply 120 V/1~/50..60 Hz	Supplied by others!	20 A, fast acting
<b>H1</b>	Bench heating	 <b>Observe safety notes in <a href="#">chapter 5.3.4.12!</a></b>	Maximum load: 0.75 kW
<b>H2</b>	Wall heating	 <b>Observe safety notes in <a href="#">chapter 5.3.4.12!</a></b>	Maximum load: 0.75 kW
<b>J1</b>	Cable bridge	Connect cable bridge to terminal block "X6", if no safety devices are connected to terminal block "X6".	
<b>J2</b>	Cable bridge	Connect cable bridge to terminals 2 and 3 of terminal block "X2", if no door switch is connected.	
<b>J3</b>	Cable bridge	<b>Do not remove!</b>	
<b>J4</b>	Cable bridge	Connect cable bridge to terminal block "X2", if no overtemperature switch "A6".	
<b>JP1</b>	Terminating resistor CAN BUS	Remove jumper, if both CAN BUS connectors are used.	
<b>M1</b>	Fragrance pump 1	 <b>DANGER: 120 V output!</b>	Maximum load: 250 V, 0.5A
<b>M3</b>	Fan 1 (single-stage)	Control of supply and exhaust fan (configurable)	Maximum load: 250 V, 1 A
<b>M4</b>	Fan 2 (single-stage)	Control of supply and exhaust fan (configurable)	Maximum load: 250 V, 1 A
<b>RJ45</b>	Network connector	Network connector for the upload of software updates	
<b>Rel 8</b>	Potential-free relay contact	Used for the control of the bench heating	Maximum load: 250 V, 6.3 A
<b>Rel 9</b>	Potential-free relay contact	Used for the control of the wall heating	Maximum load: 250 V, 6.3 A
<b>SC</b>	Safety loop		
<b>SF</b>	Ferrite CAN BUS		
<b>SW1</b>	Rotary switch unit address	See notes in <a href="#">chapter 5.3.4.16</a>	
<b>S1</b>	Door switch		
<b>S2</b>	Start-/Stop button		
<b>S3</b>	Light 1 button		
<b>S4</b>	Light 2 / Steam blast button		
<b>Q</b>	External main switch (all-pole disconnection) power supply	Supplied by others!	
<b>V1</b>	Valve cabin shower	 <b>DANGER: 120 V output!</b>	Maximum load: 250 V, 0.5A

## 5.3.4 Installation work external connections


### 5.3.4.1 Connection of switch "S1" and buttons "S2" to "S4"



### 5.3.4.2 Connection of the temperature sensor "A1" for monitoring the cabin temperature




#### 5.3.4.3 Connection of the humidity sensor "A2"



The humidity sensor is connected according to the wiring diagram to terminals "1" (24V), "2" (HUM OUT) and "3" (GND) of terminal block "X15" on the SPA control board.

The following control signals are supported: 0-5V, 1-5V, 0-10V, 2-10V, 0-20V, 0-16V, 3-16V, 0-20mA, 4-20mA, On/Off and 0-4V.


#### 5.3.4.4 Connection of the temperature sensor "A3" of the bench heating



The temperature sensor "A3" for detecting the temperature of the bench heating is connected according to the wiring diagram to the terminals "1" (+) and "2" (-) of the terminal block "X38" on the SPA control board.

The following sensors are supported: KTY, PT100 and PT1000.


### 5.3.4.5 Connection of the temperature sensor "A4" of the wall heating



The temperature sensor "A4" for detecting the temperature of the wall heating is connected according to the wiring diagram to the terminals "9" (+) and "10" (-) of the terminal block "X1" on the SPA control board.

The following sensors are supported: KTY, PT100 and PT1000.


### 5.3.4.6 Connection of the demand signal "A5" for controlling the steam generator




The demand signal "A5" for controlling the steam generator (Condair EL, Condair RS, etc.) is connected according to the wiring diagram to the terminals "1" (+) and "2" (-) of the terminal block "X26" on the SPA control board.

The output signal for the demand signal is 0-10 V and corresponds to a demand range of 0-100%.


For the connection of the demand signal to the steam generator, please refer to the following diagrams and the instructions in the documentation for the respective steam generator (Condair EL, Condair RS, etc.).



#### 5.3.4.7 Connection of the cabin overtemperature switch "A6"



### 5.3.4.8 Connection of fragrance pumps "M1" and "M2" (120 VAC)



#### Notes:

- It is important to make sure that the fragrance oil cannot flow back into the steam generator. Always place fragrance injector in descending steam pipe section near the steam inlet.
- Furthermore make sure that steam cannot flow back to the fragrance pump in case you run out of fragrance oil. Make a loop in the fragrance hose which acts as a siphon (min. diameter 100 mm) to prevent steam flowing back to the pump (see also separate installation instructions supplied with the fragrance pump).





Fig. 8: Fragrance injection installation

#### 5.3.4.9 Connecting the cabin light "E1" and "E2"




The cabin light "E1" (light 1) and "E2" (light 2) are connected according to the wiring diagram to the corresponding terminals of terminal block "X22" on the SPA control board inside the Condair Delta SPA Control Box. Depending on the lamps used, the cabin light is supplied either via the internal 120 VAC supply or via an external power supply.

Note: If a different supply voltage is required (voltage range 12-250 VAC or DC), an external power supply can be connected to terminals "1" and "2" of terminal block "X22".


The cross-section of the connecting cables must comply with the applicable local regulations.

The maximum load is: 250 V, 1 A


### 5.3.4.10 Connection of the fans "M3"/"M4" (two fan operation)



### 5.3.4.11 Connection of the optional bench heating for steam bath application



### 5.3.4.12 Connection of the bench heating and the wall heating for Caldarium and Rasul application



The bench heating "H1" ("L1", "N" and "PE") and the wall heating "H2" ("L1", "N" and "PE") are connected according to the electrical diagram with three-pole cables to the corresponding plug-in terminals and contactor terminals inside the Condair Delta SPA Control Box.

Connecting the cables to the plug-in terminals: Insert the stripped cable ends into the opening as far as they will go.

**Important:** Stranded cables must be provided with wire end ferrules for connection to the terminals.

The cross-section of the connecting cables must comply with the applicable local regulations.




**Caution:** When wiring the bench heating and the wall heating, make sure that the intended neutral connection is used inside the Condair Delta SPA Control Box.



**Caution:** Use only intrinsically safe bench heatings and wall heatings that have an overtemperature shutdown or have an overtemperature switch connected to the safety loop "SC".

**The maximum load is: bench heating 0.75 kW, wall heating 0.75 kW**

### 5.3.4.13 Connection of the relays "Rel 8" and "Rel 9"



The potential-free relay contacts "Rel 8" and "Rel 9" (for steam bath application) or "Rel 9" (for steam bath application with bench heating) can be used to control components like loudspeakers, additional light, etc. in the SPA cabin. These components are connected according to the wiring diagrams shown above to the corresponding terminals inside the Condair Delta SPA Control Box.

The relais are supplied either via the internal 120 VAC supply or via an external power supply.


The cross-section of the connecting cables must comply with the applicable local regulations.

**The maximum load is: 250 V, 12 A**

Notes:

- For the Caldarium and Rasul applications, the relay contacts "Rel 8" and "Rel 9" are used to control the bench heating and wall heating.
- For the steam bath application with bench heating, the relay contact "Rel 8" is used to control the optional bench heating.
- The function of the relay contacts is programmable via the SPA control software.

#### 5.3.4.14 Connection of the fault output "Err. Out"




The potential-free "Err. Out" contact can be used for error signaling to external devices. In normal operation (no errors present) the contact between 1-3 is closed. In the event of a fault (a warning is not considered an error), the contact between 1-2 is closed.

Note: When the device is switched off, the contact is in the idle position between 1-2.

The cross-section of the connecting cables must comply with the applicable local regulations.

**The maximum contact load is: 250 V, 3 A**

#### 5.3.4.15 Connection of external safety chain



The potential-free contacts of external monitoring devices "B3" (e.g. emergency stop) and "B4" (safety device sauna heater) of the external safety chain "SC" are connected according to the wiring diagram in series (if more than one monitoring device is connected) to the terminals of terminal block "X6" to the SPA control board inside the Condair Delta SPA Control Box.


**Note:** If no monitoring devices are connected to the terminals of terminal block "X6", a wire jumper ".J1" must be connected to the terminals.

The safety chain is operated with 24 VDC. In the event of a fault, the safety contact is opened, thus interrupting the safety chain. Use only approved 24 VDC safety devices.




**CAUTION! Do not apply any external voltage via the contacts of the external monitoring devices "B3" and "B4" to terminal "X6"!**

### 5.3.4.16 Connecting the external SPA display(s) (accessory)



**Connection of the SPA displays to the  
Condair SPA Control Box in combination with Condair Omega**



If a Condair Omega is used in combination with a Condair Delta SPA Control Box, the CAN BUS connector "X24" of the Condair Delta SPA Control Box must be connected via a CAN BUS cable without "24 V" conductor (cable No. 2) to the CAN BUS connector "X24" inside the control compartment of the Condair Omega.

The external SPA displays "D1" and "D2", which are available as accessories, are connected according to the connection diagram (see above) via a CAN BUS cable (cable no. 1) to the CAN BUS connector "X25" in the Condair Delta SPA Control Box or Condair Omega, respectively.

To both SPA displays "D1" (or "D0") and "D2" additional SPA displays (total 8 SPA displays) can be connected via the CAN BUS. Detailed instructions can be found in the separate manual supplied with the external SPA displays.

**Note:** With the Condair Omega with integrated SPA display "X0" (option) the display is connected ex works to the CAN BUS connection "X25".


**Important:** If displays are connected to both CAN BUS ports ("X25" and "X24") of the SPA control board of the the Condair Omega or the Condair Delta SPA Control Box, the jumper "JP1" (terminating resistor) on the SPA control board must be removed (see wiring diagrams in [chapter 5.3.3](#)).

**Important:** If a Condair Delta SPA Control Box is used in combination with a Condair Omega, the rotary switch "SW1" on the SPA control board of the Condair Delta SPA Control Box must be set to position "0" and the one on the SPA control board of the Condair Omega to position "1".


## Connecting the CAN BUS cable

1. Lead the CAN BUS cable(s) (4-wire, shielded, 0.34 mm<sup>2</sup> per strand) via cable glands from below into the control compartment of the Condair Omega or into the Condair Delta SPA Control Box.
2. Guide the CAN BUS cable(s) in a loop through the ferrite ring(s) as shown in [Fig. 11](#).
3. Cut the CAN BUS cable(s) to length. Prepare the cable end(s) as shown in [Fig. 9](#) (SPA Display connection) or [Fig. 10](#) (connection cable Condair Delta SPA Control Box to Condair Omega), then connect the prepared cable ends to the the CAN BUS connectors.

Important: On the CAN BUS cable between the Condair Delta SPA Control Box ("X24") and the Condair Omega ("X24") the 24V conductor must be cut off not be connected to the CAN BUS connector, otherwise the system may not function properly.




*Fig. 9: Prepare CAN BUS cable for SPA Display connection*



*Fig. 10: Prepare CAN BUS cable for the connection between Condair Delta SPA Control Box and Condair Omega*



4. Connect the prepared CAN BUS cable(s) to the corresponding connectors "X25" and/or "X24" on the control board of the Condair Omega according to the applicable diagram in this chapter.

5. Free the shielding of the CAN BUS cable(s) by removing the insulation at the appropriate position. Then, pinch the freed shielding of the CAN BUS cable(s) into the clamp holder(s) on the right side of the Condair Delta SPA Control Box or in the bottom of the Condair Omega housing, respectively.




*Fig. 11: Leading the cable through the ferrite ring and secure the cable shield in the clamp holder*

### 5.3.4.17 Power supplies

Power supply Condair Delta SPA Control Box for steam bath application	
Klemmenauslegung Standardversion	Klemmenauslegung Bench heating
 <p>Condair Delta SPA Control Box</p> <p>Q  </p> <p>F7</p> <p>L1 N PE</p> <p>120 V/1~/50..60 Hz</p>	 <p>Condair Delta SPA Control Box</p> <p>Q  </p> <p>F7</p> <p>L1 N PE</p> <p>120 V/1~/50..60 Hz</p>
<p>The 120 V/1~/50..60Hz power supply ("L1", "N" and "PE") for the Condair Delta SPA Control Box for steam bath application is connected according to wiring diagram to the corresponding plug-in terminals ("L1", "N" and "PE") inside the Condair Delta SPA Control Box.</p> <p>Connecting the cables to the plug-in terminals: Insert the stripped cable ends into the opening as far as they will go.</p> <p><b>Important:</b> Stranded cables must be provided with wire end ferrules for connection to the terminals.</p> <p>The installation of the <b>fuses "F7"</b> (without bench heating: <b>10 A, fast acting</b>, with bench heating: <b>16 A, fast acting</b>) and the <b>electrical isolator "Q"</b> (all pole disconnecting device with a minimum contact clearance of 3 mm, supplied by others) in the mains supply line are mandatory.</p> <p>The electrical isolator must be mounted in direct proximity of the Condair Delta PSA Control Box (max. distance 1 m) and must be easily accessible.</p>	
<p> <b>CAUTION!</b> Make sure that the local mains voltage corresponds to the voltage value of 120 V/1~/50..60Hz stated on the wiring diagram. Otherwise, do not connect the Condair Delta SPA Control Box.</p> <p>The cable cross-section of the mains cable must comply with the applicable local regulations.</p>	

## Power supply Condair Delta SPA Control Box for Caldarium and Rasul application

Terminal layout  
bench and wall heating



The 120 V/1~/50..60Hz power supply ("L1", "N" and "PE") for the Condair Delta SPA Control Box and the bench and wall heating for Caldarium and Rasul applications is connected according to wiring diagram to the corresponding plug-in terminals ("L1", "N" and "PE") inside the Condair Delta SPA Control Box.

Connecting the cables to the plug-in terminals: Insert the stripped cable ends into the opening as far as they will go.

**Important:** Stranded cables must be provided with wire end ferrules for connection to the terminals.

The installation of the **fuses "F7" (20 A, fast acting)** and the **electrical isolator "Q"** (all pole disconnecting device with a minimum contact clearance of 3 mm, supplied by others) in the mains supply line are mandatory.

The electrical isolator must be mounted in direct proximity of the Condair Delta PSA Control Box (max. distance 1 m) and must be easily accessible.



**CAUTION!** Make sure that the local mains voltage corresponds to the voltage value of 120 V/1~/50..60Hz stated on the wiring diagram. Otherwise, do not connect the Condair Delta SPA Control Box.

The cable cross-section of the mains cable must comply with the applicable local regulations.

### 5.3.5 Connection data accessories

#### Maximum power consumption accessories for Condair Delta SPA Control Box

Application	Accessories								
	Light		Ventilation	Fragrance		Additional relay	Shower	Heating	
	Cleaning light (Light 1)	Color Light (Light 2)	Supply air fan (Fan 1)	Exhaust fan (Fan 2)	Fragrance 1 (Pump 1)	Fragrance 2 (Pump 2)	Music, ... (Rel 8)	Music, ... (Rel 9)	Bench heating (Rel 8)
Steam bath	max. 1 kW					-	max. 0.75 kW	-	
Caldarium	max. 0.5 kW					-	max. 0.75 kW	max. 0.75 kW	
Rasul	max. 0.5 kW					max. 0.75 kW	max. 0.75 kW		

#### Connection data accessories

Application	Hardware variant	Control voltage accessories	Control power accessories max. in kW	Cable cross section supply line in mm <sup>2</sup>	Fuse F5 fast acting in A
Steam bath	SPA Control with standard equipment	120V/1~/50...60Hz	1	1.5	10
Steam bath with bench heating	SPA Control with equipment for bench heating	120V/1~/50...60Hz	1.75	2.5	16
Caldarium	SPA Control with equipment for bench and wall heating	120V/1~/50...60Hz	2	2.5	20
Rasul	SPA Control with equipment for bench and wall heating	120V/1~/50...60Hz	2	2.5	20

### 5.3.6 Inspecting the electrical installation

Check the following points:

- Does/do the supply voltage(s) for the respective SPA application meet the specifications in the corresponding wiring diagram and is/are the power supply/supplies and is/are the power supply/supplies connected in accordance with the wiring diagram?
- Is the power supply correctly fused (fuse value "F7" see wiring diagrams in [chapter 5.3.3](#))?
- Is the electrical isolator "Q" installed in the power supply line?
- Are all components correctly connected according to the wiring diagram?
- Are all connecting cables fastened?
- Are the connecting cables free of tension (passed through cable glands?)
- Have splash-proof cable glands been used?
- Does the electric installation meet the applicable local regulations for electric installations?
- Is a approved safety device (e.g. protective cover) attached to the sauna heater and is the corresponding safety device connected in series via the safety loop "SC"?
- Have intrinsically safe bench and wall heatings been used or has a corresponding overtemperature switch been integrated in series into the safety loop "SC"?
- Have the maximum capacities for the cabin volume used not been exceeded?
- Have the maximum power consumptions for the accessories been complied with (see [chapter 5.3.5](#))?
- Is the housing cover relocated and locked with the two screws and gaskets?

# 6 Appendix

## 6.1 Dimensions of the Condair Delta SPA Control Box




Fig. 12: Dimensions of the Condair Delta SPA Control Box (dimensions in inches (mm))

**Notes**

**Notes**

# Warranty

---

Condair Inc. or Condair Ltd. (depending on the entity that supplied the product, and hereinafter collectively referred to as CONDAIR) warrant for a period of two years after installation or 30 months from the manufacturer's ship date, whichever date is earlier, that CONDAIR's manufactured and assembled products, not otherwise expressly warranted, are free from defects in materials and workmanship. Notwithstanding the foregoing, the products listed below have an alternate warranty period:

- GS/GSTC Series heat exchanger(s) are warranted to be free from defects in materials and workmanship for a period of 3 years from installation or 40 months from the manufacturer's ship date, whichever is earlier.
- SAM-e Short Absorption Manifolds, except for the coupling seals, are warranted to be free from defects in materials and workmanship for a total period of 10 years from the manufacturer's ship date.
- Humilife RH, RH2+ and WH humidifiers are warranted to be free from defects in materials and workmanship for a period of 5 years from the manufacturer's ship date. CONDAIR may, at its discretion, replace individual components or Humilife RH units as a whole.
- Spare Parts used for repairs are warranted for the balance of the term of the warranty on the original humidifier or 90 days, whichever is longer.
- No warranty is made against corrosion, deterioration, or suitability of substituted materials used as a result of compliance with government regulations.

CONDAIR's obligations and liabilities under this warranty are limited to furnishing replacement parts to the customer, F.O.B. CONDAIR's factory. The replacement parts are warranted for the balance of the term of the warranty on the original humidifier or 90 days, whichever is longer. Procedure:

1. Customer Requests Warranty as per instructions on the CONDAIR Warranty Form.
2. CONDAIR reviews the warranty claim and will respond in one of two ways:
  - a. Warranty Accepted – Replacement Part or credit granted.
  - b. Warranty Declined – Response with justification will be provided to the customer.
3. In some cases, CONDAIR may request the part to be returned, freight prepaid by the customer, as part of the warranty acceptance or warranty determination process. Some reasons include:
  - a. Part must be analyzed to determine the root cause of failure.
  - b. Part must be returned to the supplier for claim/investigation.

When parts are requested to be returned, replacement parts will be sent by CONDAIR to the customer against an invoice from CONDAIR paid by the customer. The cost of the replacement parts will be reimbursed to the customer with a credit note after the parts are received and analyzed by CONDAIR, if the warranty is accepted.

The warranties set forth herein are in lieu of all other warranties expressed or implied by law. No liability whatsoever shall be attached to CONDAIR until said products have been paid for in full and then said liability shall be limited to the original purchase price for the product. Any further warranty, with the exception of a purchased extended warranty described below, must be in writing, and signed by an officer of CONDAIR.

CONDAIR makes no warranty and assumes no liability unless the equipment is installed in strict accordance with the installation manual in effect at the date of purchase, and by properly qualified and licensed professionals capable of installing such equipment.

CONDAIR makes no warranty and assumes no liability whatsoever for consequential damage or damage resulting directly from misapplication, incorrect sizing, or lack of proper maintenance of the equipment.

CONDAIR makes no warranty and assumes no liability whatsoever for damage to the products, humidifier, supply lines, drain lines, steam distribution systems, or the building as a whole caused by freezing.

CONDAIR reserves the right to change the design, specifications, and performance criteria of its products without notice or obligation.

## Extended Warranty

Extended warranties are available to purchase under the conditions listed above. Extended warranties must be purchased at the time of the original equipment order.



[www.condairparts.com](http://www.condairparts.com)

Buy authentic Condair  
parts factory direct.



Would you recommend Condair?  
Take our two question survey.

**U.S.A.**

1021 6th Street  
Racine, WI 53403

**CANADA**

2740 Fenton Road  
Ottawa, Ontario K1T 3T7

TEL: 1.866.667.8321  
EMAIL: [na.info@condair.com](mailto:na.info@condair.com)  
WEBSITE: [www.condair.com](http://www.condair.com)



The Condair logo, which features a stylized 'C' shape followed by the word 'condair' in a lowercase, sans-serif font.